

WHEN THE LIGHT IN THE ROOM IS TURNED ON USING THE EXISTING SWITCH, THE SLT SENSOR IS TRIGGERED TO TRANSMIT A WIRELESS CONTROL SIGNAL TO THE ILLUMRA THERMOSTAT, WHICH IN TURN ACTIVATES THE HVAC UNIT. WHEN THE LIGHTS ARE TURNED OFF, THE HVAC UNIT REVERTS TO A SET-BACK SETTING.

